

# BTM DER Sizing for Reliability

## Usecase 2 – DER-VET Application

**EPRI**

**ELECTRIC POWER  
RESEARCH INSTITUTE**




# Overview

- Usecase2 - Size BTM DER
  - Primary objective – Meet the reliability target during outage
  - Secondary objective – Customer bill reduction during grid connected days
- Input
  - **Reliability target = 4 hours**
  - Annual load profiles (both critical load & site load), PV insolation profile and utility tariff
  - DER Parameters (unit capital cost, O&M expense, battery efficiency)
- Output
  - DER mix and size
  - New customer bill and improvements

# Site Description and Assumptions

# Customer Load Description

- Annual site and critical load profile at hourly resolution for simulation year 2017



- The peak load demand is 10.2 MW
- Peak Critical load is 2.55 MW. It is 25% of the site load.

# Utility Tariff Structure and Charges

## Utility's Demand Charge and Energy Charges

Season	Period	Hours
Summer	On Peak	12:00 – 18:00 (Weekdays)
	Mid Peak	8:00 – 12:00 & 18:00 – 23:00 (Weekdays)
	Off Peak	All other hours
Winter	Mid Peak	8:00 – 23:00 (Weekdays)
	Off Peak	All other hours

Summer			Winter		Demand Charge
On Peak	Mid Peak	Off Peak	Mid Peak	Off Peak	
\$0.262392/kWh	\$0.086152/kWh	\$0.049672/kWh	0.062392/kWh	\$0.054152/kWh	\$7.016/kW

# DER Parameters

## ■ ES Parameters

Parameter	Value
Size	To be sized by DERVET
Li Ion Capital Cost	\$800/kW + \$250/kWh
Fixed O&M	\$10/kW-yr
Round Trip Efficiency	91%

## ■ PV parameters

- 1MW PV plant – PV size is known
- PV yearly irradiance profile is given as an input (kW/rated kW)
- PV location – tied to the AC side of the grid

# Before the Microgrid (Base Case) Electricity Bill

## Annual Base Case Electricity Bill (2017)

Energy Cost	Demand Charge	Total Bill (Energy +Demand charge)
\$4,065,918	\$823,149	\$4,889,067

## 20 Year Present Value (2017-2036)

Inflation	Discount Rate	20 Year Present Value (2017-2036)
2.2%	6%	(\$66,666,609)*


*\*Negative value represents a cost*

# DER-VET Results and Discussion



# Design Summary


For the given load and PV profile, DER-VET finds an optimal Energy storage size – **2.303 MW 8.45 hr**



# Reliability Summary

- Primary objective of the designed microgrid is to meet **Reliability target of 4 hrs**

100% probability to serve critical load for outages upto 4 hours




# Financial Summary – 20 Year Net Present Value

Comparing with baseline case, costs and benefits of DER investment during grid connected days are summarized below,

CAPEX & OPEX Costs (PV & ESS)	Total Bill Savings	Net Present Value
(\$8,642,576)*	\$8,159,905	(\$482,671)*


## Financials Summary



*\*Negative value represents a cost*

# Dispatch Summary Results (Grid Connected Days)

The energy storage system charges during morning and late night and discharges in the afternoon



# Together...Shaping the Future of Electricity